

COMPUTER CONTROL IN THE PROCESS INDUSTRIES

**by Brian Roffel
Patrick Chin**



COMPUTER CONTROL IN THE PROCESS INDUSTRIES

**by Brian Roffel
Patrick Chin**



Library of Congress Cataloging-in-Publication Data

Roffel, Brian

Computer control in the process industries.

Bibliography: p.

Includes index.

1. Process control—Data processing. I. Chin, Patrick.

II. Title.

TS156.8.R64

1987

629.8'95

87-16913

ISBN 0-87371-122-X

**COPYRIGHT © 1987 by LEWIS PUBLISHERS, INC.
ALL RIGHTS RESERVED**

Neither this book nor any part may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopying, microfilming, and recording, or by any information storage and retrieval system, without permission in writing from the publisher.

LEWIS PUBLISHERS, INC.

121 South Main Street, P.O. Drawer 519, Chelsea, Michigan 48118

PRINTED IN THE UNITED STATES OF AMERICA

PREFACE

Techniques such as dead time compensation, adaptive control, and Kalman filtering have been around for some time, but as yet find little application in industry. This is due to several reasons, including:

- Articles in the literature usually assume that the reader is familiar with a specific topic and are therefore often difficult for the practicing control engineer to comprehend.
- Many practicing control engineers in the process industry have a chemical engineering background and did not receive a control engineering education.
- There is a wide gap between theory and practical implementation, since implementation is primarily concerned with robustness, and theory is not. The user therefore has to build an "expert shell" in order to achieve the desired robustness. Little is published on this issue, however.

This book tries to promote the use of advanced control techniques by taking the reader from basic theory to practical implementation. It is therefore of interest to practicing control engineers in various types of industries, especially the process industry. Graduate and undergraduate students in control engineering will also find the book extremely useful, since many practical details are given which are usually omitted in books on control engineering.

Of special interest are the simulation examples, illustrating the application of various control techniques. The examples are available on a 5-1/4" floppy disk and can be used by anyone who has access to LOTUS 1-2-3.

Chapter 1 is the introduction; Chapters 2 through 6 deal with distributed control system networks, computer system software, computer system selection, reliability and security, and batch and continuous control. Chapter 7 gives an introduction to advanced control. Chapters 8 through 11 deal with dead time compensation techniques and model identification. Chapters 12 through 14 discuss constraint control and design, and the adjustment and application of simple process models and optimization. Chapter 15 gives a thorough introduction to adaptive control, and the last two chapters deal with state and parameter estimation.

This book is a valuable tool for everyone who realizes the importance of advanced control in achieving improved plant performance. It will take the reader from theory to practical implementation.

ABOUT THE AUTHORS

Brian Roffel is Global Advisor, Advanced Computer Control at Polysar Limited. He holds a M.Eng. in chemical engineering and a Ph.D. in process control. He worked as chief senior research officer at the Twente University of Technology, and as a computer applications-engineer at Esso Chemical Canada. During 1986-87 he was adjunct professor at the Universities of Western Ontario and Waterloo. He has written many publications on process dynamics and control.

Patrick A. Chin is a Computer Control Specialist at Polysar Limited. He holds a M.Eng. in chemical engineering from McMaster University with a specialization in process control. Previously he worked as computer applications engineer at Esso Chemical Canada.

Contents

CHAPTER 1. Introduction	1
Productivity vs flexibility	1
Problems in plant automation	2
Organizational change	3
Cost estimate	3
Modern computer systems	4
Computer hardware and software	7
Application software design	8
Summary of following chapters	8
CHAPTER 2. Distributed Computer Control System Networks	11
Computer hardware	11
Peripherals	14
Distributed input/output handling	16
Major control system functions	16
Distributed control modules and nodes	18
Total distributed control	19
CHAPTER 3. Computer System Software	23
Real time processing	25
Multitask processing	25
Memory partitioning	26
Software development	27
Major activities	27
Software design	30
Software maintenance	32
CHAPTER 4. Computer System Selection	35
Hardware	36
Software	37

Instrumentation	40
Project organization	40
Previous experience	41
Maintenance	41
System integrity	42
Other considerations	42
CHAPTER 5. Reliability and Security	45
Dependability	46
Reliability analysis	47
Single system	48
Redundancy	51
Integrity	54
Literature data	54
Security	56
CHAPTER 6. Batch and Continuous Process Control	59
Some specific problems in batch control	60
Functions of a batch control package	63
Benefits of batch control	65
Implementation and maintenance of batch control software	66
Continuous control	67
Multivariable systems	68
Other control techniques	70
CHAPTER 7. Introduction to Advanced Control	71
Common elements in process dynamics	71
Common elements in control	74
Discrete approximations	75
z-Transform	77
Control system simulation	79
PID tuning guidelines	81
CHAPTER 8. Dead Time Compensators	83
Smith Predictor	83
Dynamic reconciliator	87
Self-tuning regulators	89
Other algorithms	90
Summary and practical suggestions	91
Examples	92
CHAPTER 9. Inferential Control and Model Identification	95
Inferential control	95
Reasons for inferential control	96

Inferential variable selection	98
Dynamic considerations	99
Examples	101
Model identification	103
CHAPTER 10. Feed-Forward Control	109
Ratio control	110
True feed-forward control	111
Feed forward in a Smith Predictor	112
Feed forward in dynamic reconciliation	118
Examples	122
CHAPTER 11. Interaction and Decoupling	127
The relative gain matrix	127
The matrix method	128
Example	130
Dynamic relative gain	131
Decoupling in a Smith Predictor	132
Decoupling in dynamic reconciliation	136
Matrix approach to multivariable systems	140
Practical considerations	141
Examples	141
CHAPTER 12. Constraint Control	145
Hard constraints	145
Soft constraints	147
Control near one constraint	148
Control near multiple constraints	151
Steady state approach	153
CHAPTER 13. Design, Adjustment, and Application	
of Process Models	157
Types of process models	157
Design of a process model	159
Static empirical models	159
Dynamic empirical models	160
Practical examples	161
Adjustment of on-line models	163
Application	165
State estimation in dynamic models	166
Applications of predictions	168
CHAPTER 14. Optimization	169
Dynamic optimization	169

Static optimization	170
Objective function	171
Advisory control	172
Closed loop control	172
Optimization in industry	172
Parallel units	177
Constraint optimization	178
CHAPTER 15. Self-Tuning and Adaptive Controllers	181
Self-tuning control	181
Process and disturbance model	184
Constrained input control	187
Selection of the sampling interval	189
Some special cases	190
Least squares estimation	191
Self-tuning feed-forward control	193
Estimator initialization and convergence	194
Application to a process without delay	194
Application to a process with two periods of delay	196
CHAPTER 16. State Observers	203
State estimation	203
Structure of an observer	205
Determination of estimation errors	207
Selection of the gain G	209
Illustration	210
CHAPTER 17. Kalman Filtering	213
Process noise	213
Structure of the Kalman filter	215
Determination of estimation errors	217
Variance of the estimation errors	218
Minimization of the variances of the estimation errors	220
Results	221
Comparison to the literature	224
Illustrations	226
Summary	234
Literature	237
Nomenclature	247
Index	253

List of Figures

1.1	Local plant automation system	5
1.2	Hierarchy of activities in process control	6
1.3	Simplified structure of a computer system	7
2.1	Von Neumann computer structure	11
2.2	Harvard computer structure	12
2.3	Memory hierarchy according to Boullart et al.	13
2.4	Central processing-oriented communications structure.....	14
2.5	Data highway-oriented communications structure.....	14
2.6	System with distributed peripheral handling.....	17
2.7	General purpose control module (GPCM)	18
2.8	Cluster-based communication system.....	20
2.9	Total distributed control system	20
3.1	An example of the structure of an operating system.....	24
3.2	Memory allocation	26
3.3	Hierarchical software team structure	28
3.4	Major activities in a software project	29
3.5	Flow diagram	30
3.6	Pseudo-code	31
5.1	DDC process control with digital back-up	46
5.2	Failure frequency as a function of time (bathtub curve)	48
5.3	System flow diagram	48
5.4	Flow diagram for two parallel identical systems	52
6.1	Sequential process with common charge and dump facilities.....	61
6.2	Resin production facility	62
6.3	Noninteractive control (A) and interactive control (B)	69
7.1	Tank with level control.....	72
7.2	Response to a step change	73
7.3	Flow through a pipe	73
7.4	Step response of dead time process	74
7.5	Lead-lag response	75
7.6	PID control of 1st order/delay system in s-representation.....	80
7.7	PID control of 1st order/delay system in z-representation.....	80

8.1	Smith Predictor control block diagram	84
8.2	Alternative Smith Predictor control block diagram	86
8.3	Dynamic reconciliator control block diagram	88
8.4	Control using self-tuning regulator	89
8.5	Smith Predictor control for simulation example	93
8.6	Dynamic reconciliation applied in simulation example	94
9.1	Inferential control scheme	95
9.2	Inferential control in distillation tower	97
9.3	Temperature response of chemical reactor	100
9.4	Temperature difference response	100
9.5	Model-based control to eliminate non-minimum phase behavior	101
9.6	Distillation process in which heat and condenser duties can be used in pressure control	104
9.7	Outlet temperature response to inlet temperature change	105
9.8	Response approximation	106
9.9	Model identification using Lotus 1-2-3	108
10.1	Concept of feed-forward control	109
10.2	Ratio control in a blending system	110
10.3	Reflux to feed ratio control	111
10.4	True feed-forward in distillation	112
10.5	Analyzer control using Smith Predictor	113
10.6	Determination of feed-forward action	114
10.7	Smith Predictor with feed forward	115
10.8	Smith Predictor with feed forward in a different structure	117
10.9	Basic dynamic reconciliation using feed forward	119
10.10	Implementation of feed forward in control scheme using extended dynamic reconciliation (EDR)	120
10.11	Final control scheme using feed forward in EDR	122
10.12	Single feed-forward action in SP control strategy	124
10.13	DR with feed forward for simulation example	125
11.1	Decouplers in a 2×2 system	133
11.2	Fully decoupled 2×2 system	135
11.3	Evaluation of interaction in a decoupled system	136
11.4	Decoupled system with feed forward	137
11.5	DR structure for a 2×2 system	138
12.1	Feedback of secondary measurement to prevent wind-up	146
12.2	High and low selectors in protecting equipment	147
12.3	Classification of constraints	148
12.4	Single variable constraint control	148
12.5	Tower pressure minimization	149
12.6	Control near a constraint	152
12.7	Dynamic constraint control using a single PI controller	153
12.8	Dynamic constraint control using multiple PI controllers	154
13.1	General block diagram of a process	158

13.2	Model structure for a cracking furnace	162
13.3	Updating of process parameters	163
13.4	Model adjustment method	164
13.5	Estimation of conversion	165
13.6	Structure of a state estimator	167
14.1	Hierarchy in control	171
14.2	Closed loop optimal control	173
14.3	Olefins plant model	175
14.4	Furnace control scheme	176
14.5	Global constraint control	179
14.6	Diagram of a catalytic cracking installation	179
14.7	Operating diagram for a catalytic cracking unit	180
15.1	Self-tuning controller	182
15.2	Noisy drifting disturbance	185
15.3	Smooth disturbance	186
15.4	Constrained self-tuning controller structure	189
15.5	Process with measured disturbance	193
15.6	Setpoint and process output for first order system without delay	197
15.7	Convergence of $\hat{\beta}_0$ for first order system without delay	197
15.8	Trace as a function of time	198
15.9	Setpoint and process output for first order system with delay ($f=3$)	200
15.10	Convergence of $\hat{\beta}_0$	201
15.11	Trace for system with delay	201
16.1	Process and measurement system	204
16.2	Prediction one step ahead	206
16.3	Structure of an observer	207
16.4	Information flow diagram for the estimation error	209
17.1	Modeling of noise	214
17.2	Information flow diagram for process and measurement system	215
17.3	Prediction one step ahead	216
17.4	Structure of the Kalman filter	223
17.5	Complete information flow diagram of the Kalman filter	223
17.6	Flow diagram of simplified Kalman filter	226
17.7	Second order/delay system	226
17.8	Chemical reactor with heat transfer	230
17.9	Change of reactor inlet temperature with time	232
17.10	Estimation of concentration + = estimation \square = process	232
17.11	Estimation of activation energy	233
17.12	Change of Kalman filter gain for E/R with time $\frac{1}{2}$	234

List of Tables

1.1	Distribution of Costs for a Process Computer System	4
2.1	Some Input/Output Devices	16
3.1	Time Spent in Computer Project Activities	29
3.2	Time Spent in Coordinating a Computer Control Project	29
5.1	Comparison of Availability of Two Identical Computer Systems Installed in Two Different Plants	47
5.2	State Table for One System	49
5.3	State Table for Two Parallel Systems	52
5.4	Availability of Process Computers	55
5.5	Faults that Lead to Failures in Computer Systems	56
6.1	Recipes for Different Product Grades	64
7.1	Discrete Approximation of First Order Equation	76
7.2	Setup of Spreadsheet for Control System Simulation	80
7.3	PID Tuning Guidelines	81
8.1	A Comparison of the Dynamic Reconciliator and the Smith Predictor	92
9.1	Examples of Inferential Control	96
9.2	Temperature - Analyzer Data for a Light Ends Tower	107
10.1	Impact of Feed-Forward Action of Reflux	117
12.1	Value of F vs Percent of Process Values Allowed above the Constraint	151
17.1	Initial Estimate for Kalman Filter	233

CHAPTER 1

Introduction

Computers play an integral part in daily life. With the introduction of the chip they now are within the reach of almost everyone. Computers are being increasingly used in education, which has resulted in much greater familiarity with concepts that were known only to computer specialists 15 years ago. Nevertheless, much misconception exists regarding what a computer can do. Many people think that computers can perform miracles, but efficient software is needed for each specific task that has to be performed. There is also the tendency to use a computer in the manner that a pocket calculator has been used, that is: without knowing how it works you can still use it for many purposes.

One of the problems in many companies today is that managers are not always aware that computers for plant monitoring and control cannot be compared to the IBM-PCs on their desks. The purposes of this book are to illustrate that the introduction of computers in a plant requires much more than the purchase of hardware and software and to introduce some basic concepts that everyone who is involved in plant automation should know.

PRODUCTIVITY VS FLEXIBILITY

Computers are essential if one wants to achieve increased product quality and production flexibility in order to remain competitive. The two key words in today's competitive environment are quality and flexibility. This is also true for the chemical and petrochemical industry. Ten years ago operations were oriented toward production. High volumes were processed at relatively low cost. Even though product quality was not always good, it was less important than volume. Besides, customers did not have the equipment to analyze the product they bought and depended entirely on data provided by the product manufacturer for quality analysis.

However, more sensitive analytical equipment became available at lower prices, enabling many customers to test the materials they purchase. Sometimes, by using statistical quality control techniques, they can even determine

if they buy material which has been blended with other material to meet quality requirements.

The next decade will be characterized by decreased demand for products but higher specifications for product quality. The chemical and petrochemical process industry in particular will have to adjust to this situation by producing a larger variety of products at lower volumes with increased quality. To achieve these results effectively and economically, in-plant computers will be necessary for monitoring and improved control.

PROBLEMS IN PLANT AUTOMATION

The introduction of a process computer into a plant for monitoring and control can produce a number of problems. First, financial limitations have to be overcome. Although personal computers are continually decreasing in price, process computers are not. This is probably because they are different from any other type of computer: they are tied to a real process and therefore require extensive checking of hardware and software to make sure that the right outputs are transmitted to the field. Although the hardware may become less expensive, system software becomes more complicated in order to give increased system functionality, and this largely offsets the reduced hardware cost. For example, ten years ago process computers usually communicated with a limited number of black and white consoles. Today's systems support multiple-color operator stations.

The second problem is lack of knowledge. To control a process effectively an in-depth understanding of the process is required. Although some technology is reasonably well developed, e.g., olefins technology, there are many chemical processes which are not well understood. Operators run the plant by experience, but the computer does not have this prior knowledge base. It is important that what has to be controlled is well defined.

In order to develop a system that controls and monitors the plant, experienced personnel who are capable of translating functional specifications for process operation into computer software are required.

The computer system is usually so complicated that personnel are required to maintain and improve the computer software, whereas other specialists develop and maintain the software that runs the plant (application software). Although system software comes with the computer, application software needs to be developed because it is specific for each plant. This often requires a large number of person-years, which is often underestimated.

Another problem is that processes can change. Therefore, the resources have to be available to modify the software in order to deal with the new situation. In these cases, especially, one often finds that software that was developed some time ago is poorly documented or not documented at all. This

can lead to a waste of many person-years, and a small change may require as much time as the original design.

ORGANIZATIONAL CHANGE

The introduction of a computer system into a plant must be accompanied by a change in organization. System and application engineers will become a resident part of the plant operating personnel. The system and application engineer supervisor will have a responsible task with a wide range of activities. He must be a technical manager with enough knowledge to stimulate and support the engineers. He will have to keep abreast of new technologies in order to make sure that they can be used whenever the need arises.

On the other hand, he has to relate to process engineers, supervisors, and managers in order to create a team environment in which his engineers can best function. This is often not well understood. In many companies process engineers list their desires for plant automation and expect the application engineers to do the job. Many process supervisors and managers do not understand what is involved in using process computers and underestimate the effort required to design and implement a control, monitoring, and optimization package. Proper decisions can be made only in a team environment.

COST ESTIMATE

Recognizing that plant automation may produce some problems, it is logical to list them all and attack them one by one. After the decisions have been made on organizational change, technical support, and operations support, the computer system requirements for control, monitoring, and information processing should be defined. Once the needs are defined, one can ask for bids from computer vendors. Chapter 6 provides assistance in computer selection.

It is important to realize that the purchase of a computer will generate a number of other costs. An example of the distribution of costs for automation of a chemical plant is given in Giles and Bulloch [1] and shown in Table 1.1. Although these numbers will vary from plant to plant, they clearly indicate that computer hardware and software are only a small portion of the total cost of plant automation. A process computer makes plant automation more feasible than before, but often additional instruments, especially analytical instruments, must be purchased and installed to fully utilize the increased capability.

Table 1.1. Distribution of Costs for a Process Computer System

	Cost (%)
Computer hardware	13%
Process interface	24%
Analytical instruments	11%
Software	18%
Instrumentation engineering	8%
Application engineering	20%

MODERN COMPUTER SYSTEMS

Modern computer systems are characterized by distributed data processing. Figure 1.1 shows the structure of a local plant automation system. It may be connected to a plantwide information and management system that collects data from the various plants and stores it for further processing. The local system can also be connected to local analytical instruments, which usually have their own microcomputer.

The computer system collects data from the plant and processes it for monitoring and control purposes. Signals are converted via D/A and A/D converters, digital to analog, and analog to digital converters.

Usually two data channels are used for communication in order to increase the total system reliability. As will be discussed in a later chapter, data channels are the most critical part of modern computer systems.

There are a number of tasks for the computer system, as shown in Figure 1.2 [2]. Although these tasks will be dealt with in detail in a later chapter, they will be briefly reviewed here.

Planning is the highest level of activity. At this level the distribution of raw materials and products is controlled. The process plants have to be operated in such a way that inventories are maintained. When there are many plants involved, a complex problem is created, which is often solved off-line on a mainframe computer. There is an increasing tendency, however, to perform these activities on an on-line plant management system, which is connected to all process computers.

The next level of activity is control of the mode of operation. This indicates that during a certain period, certain products must be made out of certain raw materials. Each mode of operation can be improved by applying optimization of throughput, and so on. This activity can be done in the process control computer; the optimization of large and complex plants is often performed by a separate computer. The result of the optimization is the calculation of set-points (desired values) for the lower level of control, e.g., impurities in distillation tower overhead and bottom compositions.

Next is the level where quality control takes place. A large part of this book